



NOTE:

USE 4" PIPING AND GATE VALVE FOR 10" AND SMALLER WATER MAINS.
USE 6" PIPING AND GATE VALVE FOR 12" AND LARGER WATER MAINS.

REVISION DATE		MADERA VALLEY WATER COMPANY		Std. Dwg.
20JAN20		BLOWOFF ASSEMBLY		W-4
20OCT21				
		N.T.S.		