



**NOTES:**

1. ALL THRUST BLOCKS TO BE POURED AGAINST UNDISTURBED SOIL, WITH A MINIMUM THICKNESS OF 12 INCHES BETWEEN FITTINGS AND SOIL.
2. ALL DIMENSIONS SHOWN ARE MINIMUM, SEE THRUST BLOCK BEARING AREA CHART.
3. CONCRETE SHALL BE CLASS "B" PER STATE OF CALIFORNIA DEPT. OF TRANSPORTATION STANDARD SPECIFICATIONS, CURRENT EDITION.
4. SUPPORT AND PROTECT ALL PIPE. CONCRETE SHALL NOT BEAR AGAINST PIPES.

REVISION DATE	MADERA VALLEY WATER COMPANY	Std. Dwg.
	THRUST BLOCK DETAILS	W-5